



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J012157

BCK - IBI Group

Project Name: UNION ENDICOTT CSD - AGM

Dean Jordan
 59-61 Court Street
 Binghamton, NY 13901

Project / PO Number: N/A
 Received: 09/25/2020
 Reported: 10/14/2020

Analytical Testing Parameters

Client Sample ID:	AGM-101 FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 6:24
Lab Sample ID:	J012157-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2123	LLW

Client Sample ID:	AGM-102 FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 6:25
Lab Sample ID:	J012157-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2129	LLW

Client Sample ID:	AGM-103 FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 6:23
Lab Sample ID:	J012157-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2131	LLW

Client Sample ID:	AGM-104 FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 6:22
Lab Sample ID:	J012157-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2133	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-105 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:18
Lab Sample ID: J0I2157-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2135	LLW

Client Sample ID: AGM-106 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:17
Lab Sample ID: J0I2157-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.015 AL	0.0010	mg/L		10/08/20 1410	10/09/20 0940	LLW

Client Sample ID: AGM-107.7 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:15
Lab Sample ID: J0I2157-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2137	LLW

Client Sample ID: AGM-107.8 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:15
Lab Sample ID: J0I2157-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2142	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-108 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:12
Lab Sample ID: J0I2157-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2144	LLW

Client Sample ID: AGM-109 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:11
Lab Sample ID: J0I2157-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2146	LLW

Client Sample ID: AGM-110 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:06
Lab Sample ID: J0I2157-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0157	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2148	LLW

Client Sample ID: AGM-111 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:07
Lab Sample ID: J0I2157-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2150	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-112 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:08
Lab Sample ID: J0I2157-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2154	LLW

Client Sample ID: AGM-113 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:09
Lab Sample ID: J0I2157-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0102	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2156	LLW

Client Sample ID: AGM-114 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:09
Lab Sample ID: J0I2157-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2158	LLW

Client Sample ID: AGM-115 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:00
Lab Sample ID: J0I2157-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2200	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-116 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:01
Lab Sample ID: J0I2157-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2206	LLW

Client Sample ID: AGM-117 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:01
Lab Sample ID: J0I2157-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0207	0.015 AL	0.0010	mg/L		10/08/20 1410	10/09/20 0942	LLW

Client Sample ID: AGM-118 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:03
Lab Sample ID: J0I2157-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2208	LLW

Client Sample ID: AGM-119 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:03
Lab Sample ID: J0I2157-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2210	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-120 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:04
Lab Sample ID: J0I2157-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0067	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2212	LLW

Client Sample ID: AGM-121 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:45
Lab Sample ID: J0I2157-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.015 AL	0.0010	mg/L		10/08/20 1410	10/09/20 0944	LLW

Client Sample ID: AGM-122IM FIRST DRAW IM Ice Machine	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:52
Lab Sample ID: J0I2157-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/08/20 1410	10/09/20 0946	LLW

Client Sample ID: AGM-122SA FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:49
Lab Sample ID: J0I2157-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		10/07/20 1620	10/07/20 2214	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-122SB FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:49
Lab Sample ID: J0I2157-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0075	0.015 AL	0.0010	mg/L		10/08/20 1106	10/12/20 1242	LLW

Client Sample ID: AGM-122SC FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:50
Lab Sample ID: J0I2157-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0203	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1224	LLW

Client Sample ID: AGM-122SD FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:51
Lab Sample ID: J0I2157-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0200	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1226	LLW

Client Sample ID: AGM-122SE FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:51
Lab Sample ID: J0I2157-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1228	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID:	AGM-124.4T FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 5:48
Lab Sample ID:	J0I2157-29		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0939	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1230	LLW

Client Sample ID:	AGM-125.2 FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 5:57
Lab Sample ID:	J0I2157-30		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0552	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1232	LLW

Client Sample ID:	AGM-126.1 FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 5:58
Lab Sample ID:	J0I2157-31		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0113	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1237	LLW

Client Sample ID:	AGM-127.2 FIRST DRAW S Faucet, Cold	Collected By:	JORDAN/EICHE
Sample Matrix:	Drinking Water	Collection Date:	09/23/2020 5:58
Lab Sample ID:	J0I2157-32		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1239	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-128BF FIRST DRAW BF Bottle Filler	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:46
Lab Sample ID: J0I2157-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1241	LLW

Client Sample ID: AGM-129SA FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:04
Lab Sample ID: J0I2157-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1243	LLW

Client Sample ID: AGM-129SB FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:04
Lab Sample ID: J0I2157-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0050	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1244	LLW

Client Sample ID: AGM-131.1 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 5:44
Lab Sample ID: J0I2157-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1248	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Client Sample ID: AGM-133.1SA FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:21
Lab Sample ID: J0I2157-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0087	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1250	LLW

Client Sample ID: AGM-133.1SB FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:21
Lab Sample ID: J0I2157-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1252	LLW

Client Sample ID: AGM-200.8 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:11
Lab Sample ID: J0I2157-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1254	LLW

Client Sample ID: AGM-200.9 FIRST DRAW S Faucet, Cold	Collected By: JORDAN/EICHE
Sample Matrix: Drinking Water	Collection Date: 09/23/2020 6:14
Lab Sample ID: J0I2157-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/08/20 1106	10/08/20 1259	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2157

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.***

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 10/14/2020 21:31

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Chain of Custody



J 0 I 2 1 5 7

Customer: IBI GROUP
 Contact: DEAN JORDAN
 Project:

IBI Group
 PM: Shannon Weeks

School County: BROOME
 School Type: ELEMENTARY
 School Name: UNION ENDICOTT CSD
 School ID: ANN G MCGUINNESS
 Sampling Event Name: 2020 LEAD IN WATER
 Building address:
 Building ID:

Sampled By: JORDANEICHE
 Sampler Phone #: 607-427-5177

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	Fixture Area Type	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Lead
										Date	Time	Date	Time	
1	AGM-101	FIRST DRAW	S	Faucet, Cold								2020-09-23	624	X
2	AGM-102	FIRST DRAW	S	Faucet, Cold								2020-09-23	625	X
3	AGM-103	FIRST DRAW	S	Faucet, Cold								2020-09-23	623	X
4	AGM-104	FIRST DRAW	S	Faucet, Cold								2020-09-23	622	X
5	AGM-105	FIRST DRAW	S	Faucet, Cold								2020-09-23	618	X
6	AGM-106	FIRST DRAW	S	Faucet, Cold								2020-09-23	617	X
7	AGM-107.7	FIRST DRAW	S	Faucet, Cold								2020-09-23	615	X
8	AGM-107.8	FIRST DRAW	S	Faucet, Cold								2020-09-23	615	X
9	AGM-108	FIRST DRAW	S	Faucet, Cold								2020-09-23	612	X
10	AGM-109	FIRST DRAW	S	Faucet, Cold								2020-09-23	611	X
11	AGM-110	FIRST DRAW	S	Faucet, Cold								2020-09-23	606	X
12	AGM-111	FIRST DRAW	S	Faucet, Cold								2020-09-23	607	X
13	AGM-112	FIRST DRAW	S	Faucet, Cold								2020-09-23	608	X
14	AGM-113	FIRST DRAW	S	Faucet, Cold								2020-09-23	609	X
15	AGM-114	FIRST DRAW	S	Faucet, Cold								2020-09-23	609	X
16	AGM-115	FIRST DRAW	S	Faucet, Cold								2020-09-23	600	X
17	AGM-116	FIRST DRAW	S	Faucet, Cold								2020-09-23	601	X
18	AGM-117	FIRST DRAW	S	Faucet, Cold								2020-09-23	601	X
19	AGM-118	FIRST DRAW	S	Faucet, Cold								2020-09-23	603	X
20	AGM-119	FIRST DRAW	S	Faucet, Cold								2020-09-23	603	X
21	AGM-120	FIRST DRAW	S	Faucet, Cold								2020-09-23	604	X
22	AGM-121	FIRST DRAW	S	Faucet, Cold								2020-09-23	545	X
23	AGM-122IM	FIRST DRAW	IM	Ice Machine								2020-09-23	552	X
24	AGM-122SA	FIRST DRAW	S	Faucet, Cold								2020-09-23	549	X
25	AGM-122SB	FIRST DRAW	S	Faucet, Cold								2020-09-23	549	X
26	AGM-122SC	FIRST DRAW	S	Faucet, Cold								2020-09-23	550	X

