



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1F0780

BCK - IBI Group

Project Name: UNION ENDICOTT CSD

Dean Jordan  
59-61 Court Street  
Binghamton, NY 13901

Project / PO Number: N/A  
Received: 06/07/2021  
Reported: 06/26/2021

Analytical Testing Parameters

Client Sample ID:	LW-7 CLASSROOM 7 S Faucet, Cold	Collected By:	JORDAN
Sample Matrix:	Drinking Water	Collection Date:	06/02/2021 5:46
Lab Sample ID:	J1F0780-01		

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0278	0.015 AL	0.000400	mg/L		06/10/21 1827	06/10/21 1827	EMB

Client Sample ID:	LW-1.1 CLASSROOM 1 TOILET S Faucet, Cold	Collected By:	JORDAN
Sample Matrix:	Drinking Water	Collection Date:	06/02/2021 5:47
Lab Sample ID:	J1F0780-02		

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0225	0.015 AL	0.000800	mg/L		06/10/21 1428	06/11/21 1459	SEA

Client Sample ID:	LW-16 CLASSROOM 16 S Faucet, Cold	Collected By:	JORDAN
Sample Matrix:	Drinking Water	Collection Date:	06/02/2021 5:49
Lab Sample ID:	J1F0780-03		

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0648	0.015 AL	0.000800	mg/L		06/10/21 1428	06/11/21 1504	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1F0780

<b>Client Sample ID:</b> LW-34 CLASSROOM 34 S Faucet, Cold	<b>Collected By:</b> JORDAN
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 06/02/2021 5:51
<b>Lab Sample ID:</b> J1F0780-04	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.780</b>	0.015 AL	0.00400	mg/L		06/11/21 1309	06/11/21 1309	SEA

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division  
10121  
02-00257

New York State Department of Health  
PA Department of Environmental Protection  
PADEP Accreditation by Rule

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Jennifer Walker  
Operations Manager  
Reported: 06/26/2021 23:05

**Chain of Custody**

Customer: IBI GROUP  
 Contact: DEAN JORDAN  
 Project:



IBI Group  
 PM: Shannon Weeks

Sampled By: JORDAN  
 Sampler Phone #: 607-427-5177

School County: BROOME  
 School Type: ELEMENTARY  
 School Name: UNION ENDICOTT CSD  
 School ID: LINNAEUS W WEST  
 Sampling Event Name: 2020 LEAD IN WATER - 6/2021 RETEST  
 Building address:  
 Building ID:

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	Fixture Area Type	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Lead
										Date	Time	Date	Time	
1	LW-7	FIRST DRAW	S	Faucet, Cold			CLASSROOM 7					2021-06-02	546	X
2	LW-1.1	FIRST DRAW	S	Faucet, Cold			CLASSROOM 1 TOILET					2021-06-02	547	X
3	LW-16	FIRST DRAW	S	Faucet, Cold			CLASSROOM 16					2021-06-02	549	X
4	LW-34	FIRST DRAW	S	Faucet, Cold			CLASSROOM 34					2021-06-02	551	X
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														

Sampled By (signature) *[Signature]* Date/Time 6/2/21  
 Relinquished By (signature) *[Signature]* Date/Time 6/4/21  
 Relinquished By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_

Received By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_  
 Received By (signature) *[Signature]* Date/Time 6/7/21 1700  
 Received By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_