



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J011954

**BCK - IBI Group**

**Project Name: UNION ENDICOTT CSD - TJW**

Dean Jordan  
 59-61 Court Street  
 Binghamton, NY 13901

Project / PO Number: N/A  
 Received: 09/25/2020  
 Reported: 10/14/2020

**Analytical Testing Parameters**

<b>Client Sample ID:</b>	TJW 1S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 6:01
<b>Lab Sample ID:</b>	J011954-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0060	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1732	LLW

<b>Client Sample ID:</b>	TJW 1.1S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 6:01
<b>Lab Sample ID:</b>	J011954-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0049	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1737	LLW

<b>Client Sample ID:</b>	TJW 2S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 6:02
<b>Lab Sample ID:</b>	J011954-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0042	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1739	LLW

<b>Client Sample ID:</b>	TJW 2.1S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 6:02
<b>Lab Sample ID:</b>	J011954-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0085	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1741	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 3S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:02
<b>Lab Sample ID:</b> J011954-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0087	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1743	LLW

<b>Client Sample ID:</b> TJW 4S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:03
<b>Lab Sample ID:</b> J011954-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0033	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1745	LLW

<b>Client Sample ID:</b> TJW 5S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:04
<b>Lab Sample ID:</b> J011954-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0050	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1750	LLW

<b>Client Sample ID:</b> TJW 008.7 FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:07
<b>Lab Sample ID:</b> J011954-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0011	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1752	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 008.8 FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:07
<b>Lab Sample ID:</b> J011954-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1754	LLW

<b>Client Sample ID:</b> TJW 9S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:05
<b>Lab Sample ID:</b> J011954-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0097	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1756	LLW

<b>Client Sample ID:</b> TJW 10S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:06
<b>Lab Sample ID:</b> J011954-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1758	LLW

<b>Client Sample ID:</b> TJW 13S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:11
<b>Lab Sample ID:</b> J011954-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.168	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1801	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 14S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:12
<b>Lab Sample ID:</b> J011954-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0046	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1803	LLW

<b>Client Sample ID:</b> TJW 16S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:12
<b>Lab Sample ID:</b> J011954-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0037	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1805	LLW

<b>Client Sample ID:</b> TJW 18S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:16
<b>Lab Sample ID:</b> J011954-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0030	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1807	LLW

<b>Client Sample ID:</b> TJW 19S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:17
<b>Lab Sample ID:</b> J011954-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0025	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1812	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 20S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:17
<b>Lab Sample ID:</b> J011954-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0050	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1814	LLW

<b>Client Sample ID:</b> TJW 22.1S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:38
<b>Lab Sample ID:</b> J011954-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0052	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1816	LLW

<b>Client Sample ID:</b> TJW 23S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:20
<b>Lab Sample ID:</b> J011954-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0532	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1818	LLW

<b>Client Sample ID:</b> TJW 24S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:21
<b>Lab Sample ID:</b> J011954-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0217	0.015 AL	0.0010	mg/L		10/01/20 1553	10/01/20 1820	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b>	TJW 25.1S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 5:58
<b>Lab Sample ID:</b>	J011954-21		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0468	0.015 AL	0.0010	mg/L		10/02/20 1328	10/05/20 1502	LLW

<b>Client Sample ID:</b>	TJW 29S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 6:22
<b>Lab Sample ID:</b>	J011954-22		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0113	0.015 AL	0.0010	mg/L		10/02/20 1328	10/05/20 1505	LLW

<b>Client Sample ID:</b>	TJW 31S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 6:23
<b>Lab Sample ID:</b>	J011954-23		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0092	0.015 AL	0.0010	mg/L		10/02/20 1328	10/05/20 1507	LLW

<b>Client Sample ID:</b>	TJW 32S FIRST DRAW S Faucet, Cold	<b>Collected By:</b>	JORDAN/EICHE
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	09/22/2020 6:24
<b>Lab Sample ID:</b>	J011954-24		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0050	0.015 AL	0.0010	mg/L		10/02/20 1328	10/05/20 1509	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 32.1 FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:52
<b>Lab Sample ID:</b> J011954-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0118	0.015 AL	0.0010	mg/L		10/02/20 1328	10/05/20 1511	LLW

<b>Client Sample ID:</b> TJW 033S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:06
<b>Lab Sample ID:</b> J011954-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0405	0.015 AL	0.0204	mg/L	D	10/02/20 1328	10/07/20 1351	LLW

<b>Client Sample ID:</b> TJW 33.1 FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:53
<b>Lab Sample ID:</b> J011954-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0045	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1838	LLW

<b>Client Sample ID:</b> TJW 34S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:26
<b>Lab Sample ID:</b> J011954-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.729	0.015 AL	0.0010	mg/L		10/05/20 1519	10/07/20 1340	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 034.1S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:10
<b>Lab Sample ID:</b> J011954-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1845	LLW

<b>Client Sample ID:</b> TJW 35S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:26
<b>Lab Sample ID:</b> J011954-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0072	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1847	LLW

<b>Client Sample ID:</b> TJW 37S FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:27
<b>Lab Sample ID:</b> J011954-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0265	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1849	LLW

<b>Client Sample ID:</b> TJW 39SA FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:40
<b>Lab Sample ID:</b> J011954-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0067	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1851	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 39SB FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:41
<b>Lab Sample ID:</b> J011954-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0056	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1856	LLW

<b>Client Sample ID:</b> TJW 39SC FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:42
<b>Lab Sample ID:</b> J011954-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0099	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1858	LLW

<b>Client Sample ID:</b> TJW 39SD FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:46
<b>Lab Sample ID:</b> J011954-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0074	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1900	LLW

<b>Client Sample ID:</b> TJW 39IM FIRST DRAW IM Ice Machine	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:45
<b>Lab Sample ID:</b> J011954-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1902	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 39.1T FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:56
<b>Lab Sample ID:</b> J011954-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0079	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1904	LLW

<b>Client Sample ID:</b> TJW 40BF FIRST DRAW BF Bottle Filler	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:47
<b>Lab Sample ID:</b> J011954-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1907	LLW

<b>Client Sample ID:</b> TJW 040.1A FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:49
<b>Lab Sample ID:</b> J011954-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0152	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1909	LLW

<b>Client Sample ID:</b> TJW 040.2B FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 5:50
<b>Lab Sample ID:</b> J011954-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0073	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1911	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 1-4.1SB FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:24
<b>Lab Sample ID:</b> J011954-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0063	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1913	LLW

<b>Client Sample ID:</b> TJW 1-4.1SD FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:25
<b>Lab Sample ID:</b> J011954-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.47	0.015 AL	0.0100	mg/L	D	10/06/20 1339	10/07/20 1415	LLW

<b>Client Sample ID:</b> TJW 1-1SB FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:15
<b>Lab Sample ID:</b> J011954-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0276	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1918	LLW

<b>Client Sample ID:</b> TJW 1-1SC FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:16
<b>Lab Sample ID:</b> J011954-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0094	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1920	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J011954

<b>Client Sample ID:</b> TJW 1-1SD FIRST DRAW S Faucet, Cold	<b>Collected By:</b> JORDAN/EICHE
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 09/22/2020 6:17
<b>Lab Sample ID:</b> J011954-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0090	0.015 AL	0.0010	mg/L		10/05/20 1519	10/05/20 1922	LLW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- D:** The sample was diluted due to matrix interference.
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 10/14/2020 20:53

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

**Chain of Custody**



J 0 I 1 9 5 4

Customer: IBI GROUP  
 Contact: DEAN JORDAN  
 Project:



IBI Group  
 PM: Shannon Weeks

County: BROOME  
 School Type: ELEMENTARY  
 School Name: UNION ENDICOTT CSD  
 School ID: THOMAS J WATSON  
 Sampling Event Name: 2020 LEAD IN WATER  
 Building address:  
 Building ID:

Sampled By: JORDAN/EICHE  
 Sampler Phone #: 607-427-5177

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	Fixture Area Type	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Lead
										Date	Time	Date	Time	
1	TJW 1S	FIRST DRAW	S	Faucet, Cold								2020-09-22	601	X
2	TJW 1.1S	FIRST DRAW	S	Faucet, Cold								2020-09-22	601	X
3	TJW 2S	FIRST DRAW	S	Faucet, Cold								2020-09-22	602	X
4	TJW 2.1S	FIRST DRAW	S	Faucet, Cold								2020-09-22	602	X
5	TJW 3S	FIRST DRAW	S	Faucet, Cold								2020-09-22	602	X
6	TJW 4S	FIRST DRAW	S	Faucet, Cold								2020-09-22	603	X
7	TJW 5S	FIRST DRAW	S	Faucet, Cold								2020-09-22	604	X
8	TJW 008.7	FIRST DRAW	S	Faucet, Cold								2020-09-22	607	X
9	TJW 008.8	FIRST DRAW	S	Faucet, Cold								2020-09-22	607	X
10	TJW 9S	FIRST DRAW	S	Faucet, Cold								2020-09-22	605	X
11	TJW 10S	FIRST DRAW	S	Faucet, Cold								2020-09-22	606	X
12	TJW 13S	FIRST DRAW	S	Faucet, Cold								2020-09-22	611	X
13	TJW 14S	FIRST DRAW	S	Faucet, Cold								2020-09-22	612	X
14	TJW 16S	FIRST DRAW	S	Faucet, Cold								2020-09-22	612	X
15	TJW 18S	FIRST DRAW	S	Faucet, Cold								2020-09-22	616	X
16	TJW 19S	FIRST DRAW	S	Faucet, Cold								2020-09-22	617	X
17	TJW 20S	FIRST DRAW	S	Faucet, Cold								2020-09-22	617	X
18	TJW 22.1S	FIRST DRAW	S	Faucet, Cold								2020-09-22	538	X
19	TJW 23S	FIRST DRAW	S	Faucet, Cold								2020-09-22	620	X
20	TJW 24S	FIRST DRAW	S	Faucet, Cold								2020-09-22	621	X
21	TJW 25.1S	FIRST DRAW	S	Faucet, Cold								2020-09-22	558	X
22	TJW 29S	FIRST DRAW	S	Faucet, Cold								2020-09-22	622	X
23	TJW 31S	FIRST DRAW	S	Faucet, Cold								2020-09-22	623	X
24	TJW 32S	FIRST DRAW	S	Faucet, Cold								2020-09-22	624	X
25	TJW 32.1	FIRST DRAW	S	Faucet, Cold								2020-09-22	552	X
26	TJW 033S	FIRST DRAW	S	Faucet, Cold								2020-09-22	606	X

